

APPENDIX I

Alphabetical list of all 112 municipal wastewater treatment plants in Idaho that have NPDES or IPDES permits and the violations incurred over the past three years, if applicable.

FACILITY	VIOLATIONS	POLLUTANTS
Aberdeen	7	E. coli Solids, total suspended
Ahsahka	28	Chlorine E. coli Solids, suspended percent removal Solids, total suspended
American Falls	0	
Blackfoot	10	BOD, 5-day, 20 deg. C E. coli Floating solids or foam Phosphorus Solids, suspended percent removal Solids, total suspended
Boise - Lander	2	Ammonia
Boise - West	1	E. coli
Bonnars Ferry	0	
Bovill	5	BOD, 5-day, 20 deg. C E. coli Solids, total suspended
Buhl	0	
Burley	6	Ammonia Coliform, fecal general E. coli
Caldwell	12	Ammonia E. coli Floating solids or foam Solids, total suspended
Cambridge	26	BOD, 5-day, 20 deg. C BOD, 5-day, percent removal E. coli Solids, suspended percent removal Solids, total suspended pH
Carey	0	
Cascade	0	
Clarkia	6	Chlorine Solids, total suspended
Coeur d'Alene	8	BOD, carbonaceous, 5-day, 20 deg. C E. coli Solids, total suspended pH
Cottonwood	11	BOD, 5-day, 20 deg. C Chlorine E.coli
Council	38	BOD, 5-day, 20 deg. C E. coli Solids, suspended percent removal Solids, total suspended
Craigmont	39	BOD, 5-day, 20 deg. C BOD, 5-day, percent removal Chlorine E. coli Solids, suspended percent removal Solids, total suspended pH

FACILITY	VIOLATIONS	POLLUTANTS
Culdesac	16	BOD, 5-day, 20 deg. C BOD, 5-day, percent removal E. coli
Deary	23	BOD, 5-day, 20 deg. C BOD, 5-day, percent removal E. coli Solids, suspended percent removal Solids, total suspended pH
Dover	0	
Driggs	113	Ammonia BOD, 5-day, 20 deg. C Solids, suspended percent removal
Elk City	32	BOD, 5-day, percent removal E. coli Solids, suspended percent removal Temperature, water deg. centigrade pH
Elk River	5	E. coli pH
Emida	0	
Emmett	2	Coliform, fecal general E. coli
Fairfield	6	BOD, 5-day, 20 deg. C BOD, 5-day, percent removal E. coli Solids, suspended percent removal
Filer	0	
Firth	33	BOD, 5-day, 20 deg. C BOD, 5-day, percent removal Phosphorus Solids, suspended percent removal Solids, total suspended
Franklin	9	BOD, 5-day, 20 deg. C Chlorine Solids, total suspended
Fruitland (Payette)	0	
Fruitland (Snake)	0	
Genesee	74	Ammonia BOD, 5-day, 20 deg. C BOD, 5-day, percent removal Chlorine E. coli Solids, suspended percent removal Solids, total suspended
Georgetown	0	
Glenns Ferry	14	BOD, 5-day, 20 deg. C BOD, 5-day, percent removal E. coli Solids, suspended percent removal Solids, total suspended
Gooding	16	Ammonia
Grangeville	1	Solids, total suspended
Greenleaf	1	E. coli

FACILITY	VIOLATIONS	POLLUTANTS
Hagerman	104	BOD, 5-day, 20 deg. C BOD, 5-day, percent removal Chlorine E. coli Solids, suspended percent removal Solids, total suspended pH
Hailey	6	Ammonia E. coli Phosphorus
Hansen	8	Chlorine E. coli Solids, total suspended
Harrison	18	Ammonia BOD, 5-day, 20 deg. C E. coli Solids, suspended percent removal Solids, total suspended
Hayden	1	Zinc
Heyburn	16	Coliform, fecal general E. coli Phosphorus Solids, suspended percent removal Solids, total suspended
Homedale	27	BOD, 5-day, 20 deg. C BOD, 5-day, percent removal E. coli Phosphorus Solids, suspended percent removal Solids, total suspended pH
Horseshoe Bend	18	pH
Idaho Falls	7	Ammonia BOD, 5-day, 20 deg. C BOD, 5-day, percent removal E. coli
Jerome	1	Phosphorus
Juliaetta	1	Temperature, water deg. centigrade
Kamiah	0	
Kendrick	69	Ammonia BOD, 5-day, 20 deg. C BOD, 5-day, percent removal Chlorine E. coli Solids, suspended percent removal Solids, total suspended
Ketchum	0	
Kooksia	5	BOD, 5-day, 20 deg. C pH
Kootenai-Ponderay	2	Solids, suspended percent removal
Kuna	2	Ammonia
Lapwai	0	
Lava Hot Springs	0	
Lewiston	0	
Mackay	3	BOD, 5-day, percent removal Chlorine

FACILITY	VIOLATIONS	POLLUTANTS
Marsing	19	BOD, 5-day, 20 deg. C E. coli Solids, total suspended
McCall	0	
Meridian	2	Coliform, fecal general
Middleton	0	
Montpelier	11	BOD, 5-day, 20 deg. C BOD, 5-day, percent removal Chlorine Solids, suspended percent removal Solids, total suspended
Moscow	0	
Nampa	4	E. coli
New Meadows	7	Chlorine Phosphorus Solids, total suspended
New Plymouth	0	
Nezperce	76	BOD, 5-day, 20 deg. C BOD, 5-day, percent removal E. coli Solids, suspended percent removal Solids, total suspended pH
Notus	45	Ammonia BOD, 5-day, 20 deg. C E. coli Phosphorus Solids, total suspended pH
Orofino	8	Chlorine Solids, total suspended
Osburn	18	Ammonia BOD, 5-day, percent removal Cadmium Lead Solids, suspended percent removal Solids, total suspended Zinc
Parma	37	BOD, 5-day, 20 deg. C BOD, 5-day, percent removal Chlorine E. coli Phosphorus Solids, suspended percent removal Solids, total suspended
Payette	0	
Pierce	26	BOD, 5-day, 20 deg. C BOD, 5-day, percent removal Chlorine E. coli Solids, suspended percent removal Solids, total suspended
Plummer	75	Ammonia E. coli Phosphorus Solids, total suspended
Pocatello	2	Phosphorus
Post Falls	1	Zinc
Potlatch	6	BOD, 5-day, 20 deg. C E. coli Solids, total suspended

FACILITY	VIOLATIONS	POLLUTANTS
Preston	29	Ammonia BOD, 5-day, 20 deg. C BOD, 5-day, percent removal Phosphorus Solids, total suspended
Priest River	15	E. coli Solids, total suspended
Rexburg	16	Ammonia Lead Silver Solids, suspended percent removal Solids, total suspended pH
Richfield	6	BOD, 5-day, 20 deg. C E. coli Solids, total suspended
Rigby	5	BOD, 5-day, 20 deg. C
Riggins	0	
Ririe	11	BOD, 5-day, 20 deg. C BOD, 5-day, percent removal Solids, suspended percent removal Solids, total suspended
Riverside Water	11	BOD, 5-day, percent removal E. coli Solids, suspended percent removal Solids, total suspended
Roberts	0	
Rockland	0	
Saint Anthony	10	Chlorine E. coli Solids, suspended percent removal Solids, total suspended pH
Saint Maries	20	BOD, 5-day, percent removal Chlorine E. coli Solids, suspended percent removal pH
Salmon	1	E. coli
Sandpoint	16	BOD, 5-day, 20 deg. C BOD, 5-day, percent removal Chlorine E. coli Solids, suspended percent removal Solids, total suspended pH
Shelley	1	Phosphorus

FACILITY	VIOLATIONS	POLLUTANTS
Shoshone	2	Chlorine E. coli
Smelterville	25	Ammonia BOD, 5-day, 20 deg. C E. coli Lead Solids, suspended percent removal Solids, total suspended
Soda Springs	4	Ammonia E. coli Solids, suspended percent removal
South Fork Coeur d'Alene	26	Ammonia Cadmium E. coli Solids, total suspended Zinc
Star	0	
Tensed	21	BOD, 5-day, 20 deg. C Chlorine E. coli Solids, total suspended
Troy	27	BOD, 5-day, 20 deg. C E. coli Solids, total suspended
Twin Falls	2	E. coli
Viola	0	
Weippe	20	BOD, 5-day, percent removal Chlorine E. coli Floating solids or foam Solids, suspended percent removal pH
Weiser	1	BOD, 5-day, percent removal
White Bird	0	
Wilder	112	BOD, 5-day, 20 deg. C BOD, 5-day, percent removal Chlorine E. coli Solids, suspended percent removal Solids, total suspended
Winchester	26	BOD, 5-day, 20 deg. C BOD, 5-day, percent removal Chlorine E. coli Floating solids or foam Oil and grease Solids, suspended percent removal Solids, total suspended
Worley	28	Ammonia BOD, 5-day, percent removal Chlorine Solids, suspended percent removal Solids, total suspended